

**CONTRACT DOCUMENTS
BOONE COUNTY, MISSOURI
Harold Cunningham Road Slope Failure Project, Project # 9712
BID NO: 84-12DEC02**

ADDENDUM #1

This addendum is issued in accordance with the Instructions to Bidders and is hereby incorporated into and made a part of the Contract Documents. Bidders are reminded that receipt of this addendum must be acknowledged and submitted with the attached **Acknowledgment of Addendum Form (on page 5.2)**.

Drawings and specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

DRAWING CLARIFICATION:

1. Sheet 3 of 16:

Pre-bored Pile Holes- Pre-bore 24" diameter, *plus or minus 2"*, pile holes a minimum of 12 feet into competent rock or to an elevation shown on Longitudinal Retaining Wall Section or as directed by the Engineer. Pre-bored pile holes shall extend a minimum of 3 feet below any shale layers encountered.

The pile holes shall be backfilled with class F concrete. Class F concrete will not be paid for directly, but will be subsidiary to 'Pre-bore Pile Holes'.

PLEASE NOTE: This does not change the bid opening date, bids are due at the Boone County Purchasing Office, Johnson Building, 601 E. Walnut, Room 209, Columbia, Missouri, 65201-7731 until 1:15 p.m. on December 12, 2002.

The bid is scheduled to be opened after 1:30 p.m. at the Boone County Commission Chambers, Boone County Government Center 801 E. Walnut, Columbia, Missouri 65201.

Submit the Acknowledgement of Addendum One with your response to the above referenced bid or in a separate envelope clearly marked **Bid Number – 84-12DEC02– Harold Cunningham Slope Failure Project, Project #9712**, if your response has already been returned. Additional copies of the bid documents may be obtained from the Purchasing Office, 601 E. Walnut, Room 209, Columbia, MO 65201, (573) 886-4392. **Bid responses must be sent to the Boone County Purchasing Department, Boone County Johnson Building, 601 E. Walnut, Room 209, Columbia, MO 65201.** Responses are due in the Purchasing Department no later than 1:15 p.m. on December 12, 2002.

By: _____

Marlene Ridgway

Buyer

BIDDER has examined copies of Addendum #1 to Harold Cunningham Road Slope Failure Project #9712 Construction Bid Request number 84-12DEC02, receipt of which is hereby acknowledged:

Company Name _____

Address _____

Phone Number _____

Authorized Representative _____