

**CONTRACT DOCUMENT
BOONE COUNTY, MISSOURI
Maupin Lane Bridge Replacement
Bid Number 68-25SEP03**

ADDENDUM # 1

This addendum is issued in accordance with the Instructions to Bidders and is hereby incorporated into and made a part of the Contract Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with the bidder's Response Form as instructed for this format of bidding.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

BID DOCUMENTS:


ADD to bid the attached clarifications and/or modifications to be made in the plans and project manual for the above referenced bid.

The following revisions and clarifications to the Plans and Specifications have been made concerning pile driving hammers and the finishing of the deck surface.

- The use of a vibratory hammer for driving piles is acceptable as long as it satisfies the minimum hammer energy requirements.
- Machine finishing of the deck riding surface will not be required.

PLEASE NOTE:

This does not change the bid opening date. Bids are due through www.rfghosting.com not later than 2:00 p.m. CST (3:00 p.m. EST).

By: 
Marlene Ridgway
Buyer

BIDDER has examined the copy of Addendum #1 to Bid Number 68-25SEP03 – Maupin Lane Bridge Replacement, receipt of which is hereby acknowledged.

Signature of Authorized Representative

Date

Name of Authorized Representative

Company Name