

**CONTRACT DOCUMENTS  
BOONE COUNTY, MISSOURI  
BID NO: 36-01JUL04 Ludwick Blvd. Storm Drainage Improvements**

**ADDENDUM #1**  
**(Issued June 25, 2004)**


This addendum is issued in accordance with the Instructions to Bidders and is hereby incorporated into and made a part of the Contract Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with bidder's *Bid Form (section 5.1 and 5.2)*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

**BID DOCUMENTS:**

1. Construction note 10 on sheet 1 (Cover Sheet) of the plans shall be revised to read as follows:

CONTRACTOR SHALL BUILD BOX CULVERT ACCORDING TO CURRENT MoDOT STANDARDS AND SPECIFICATIONS FOR AN HS20 MODIFIED RATING. ALL REINFORCING BAR SIZES AND SPACING AND MEMBER THICKNESSES SHALL BE AS SHOWN IN THE MoDOT TABLE FOR A DOUBLE BOX CULVERT WITH A HEIGHT OF 9 FEET, SPAN OF 12 FEET AND A DESIGN FILL OF 0'-6".

By:   
Alice Winkelman, CPPB  
Buyer, Purchasing

BIDDER has examined copy of Addendum #1 to Bid Number 36-01JUL4 – Ludwick Blvd. Storm Drainage Improvements, receipt of which is hereby acknowledged:

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_

Phone Number: \_\_\_\_\_

Fax Number: \_\_\_\_\_

Authorized  
Representative Signature: \_\_\_\_\_

Date: \_\_\_\_\_