

**CONTRACT DOCUMENTS
BOONE COUNTY, MISSOURI
BID NO: 33-04MAY06 CHIP AND SEAL APPLICATION**


ADDENDUM #1
(Issued April 25, 2006)

This addendum is issued in accordance with the Introduction and General Conditions of Bidding and is hereby incorporated into and made a part of the Contract Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with bidder's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

BID DOCUMENTS:

- 1. The Contractor shall lay a test strip a minimum of 12 hours prior to the start of the event in order to calibrate the load. The oil supplier, Contractor, and County must be present during the calibration.**

By: 
Heather Turner, CPPB
Buyer, Purchasing

BIDDER has examined copy of Addendum #1 to Bid Number 33-04MAY06 Chip and Seal Application, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____

Fax Number: _____

Authorized Representative Signature: _____

Date: _____