

**CONTRACT DOCUMENTS  
BOONE COUNTY, MISSOURI  
BID #65-10AUG06 Thomas Hill Road Low Water Crossing Project**

**ADDENDUM #1**  
**(Issued August 2, 2006)**

This addendum is issued in accordance with the Introduction and General Conditions of Bidding and is hereby incorporated into and made a part of the Contract Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with bidder's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

**BID DOCUMENTS:**

1. Delete in its entirety page 2 of 4 of the plan sheets under Appendix C and replace with the "ADDENDUM COPY" of page 2 of 4 of the plan sheets, attached to and part of this addendum.
  
2. Change the page number of 15.15 to 16.1 to correspond to the table of contents. On that same page listed as **SPECIAL PROVISIONS**, add the following statement to the end of the second paragraph regarding excavation: "The remaining excavated material can be used to fill the existing hole south of the roadway and east of the existing culverts. The placed material shall be graded to the elevations as shown on page 2 of 4 of the plan sheets by the proposed contour lines and seeded, fertilized, and mulched. No backfill material containing rock, debris from rock excavation, or concrete with particle sizes having a maximum dimension larger than 3" shall be placed in the upper 18 inches of the embankment."

By:   
**Heather Turner, CPPB**  
**Senior Buyer**

BIDDER has examined copy of Addendum #1 to Request for Bid #65-10AUG06 Thomas Hill Road Low Water Crossing Project, receipt of which is hereby acknowledged:

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_

Phone Number: \_\_\_\_\_

Fax Number: \_\_\_\_\_

Authorized Representative Signature: \_\_\_\_\_

Date: \_\_\_\_\_

