



Scroggs Architecture P.C.
Stuart S. Scroggs, Principal

1008 Maplewood Dr. Columbia, MO 65203
Phone: 573-442-5600 Fax: 573-442-5611
E-mail: sss@scroggsarchitecture.com

December 18, 2006

ADDENDUM NO. 2

Bathroom Expansion/Remodel
Boone County Public Works
South Facility Maintenance Building
5551 Highway 63 South
Columbia, MO 65201
Bid Number 90-21 DEC06

Bidders are hereby informed of the following clarifications and/or modifications to be made in the plans and project manual for the above referenced project.

1. Project Manual, Division 9 Finishes, Catalog Cuts.
Clarification: "Install embossed FRP Glasboard-P manufactured by Kemlite Co. Inc. or equal, Ivory #84 color, 0.09" thickness."