



BOONE COUNTY, MISSOURI
Request for Bid #09-28FEB08 – Data and Telephone Terminations – Boone County
Courthouse Renovation Project

ADDENDUM #2 - Issued February 25, 2008

This addendum is issued in accordance with the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.

The following questions have been received for the above referenced bid and the followings responses are provided. Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

- I. Question: The bid documents do not specifically say the Cat 6 keystones are to be provided by the contractor. Please clarify.**

The contractor awarded this contract shall provide the Cat 6 keystones.

- II. Question 2: If the Cat 6 keystones are contractor furnished, what vendor brand needs to be utilized to fit the county supplied faceplates?**

The County will provide face plates to match the keystones.

- III. Question 3: Is there a color preference for the Cat 6 keystones?**

No color preference.

- IV. Question 4: How many strands are in the fiber optic cable runs? Is it a tight buffered fiber cable 62.5 or 60 micron?**

The County does not know at this time.

- V. Question 5: Who is providing the fiber enclosures and associated fiber adapter panels? Are they rack or wall-mount?**

The County is providing the fiber encloures and associated fiber adapter panels. The County does not know at this time if they are rack or wall-mount.

- VI. Question 6: Is the contractor to provide certified patch cords or will off shore assemblies be suitable?**


The Contractor shall provide certified patch cords.

- VII. Question 7: Are we to provide Cat 5E patch cords for what is to be category 6 cable installation?**

The Contractor shall provide Cat 5E patch cords for what is to be category 6 cable installation.

VIII. Question 8: In the event of damaged or improperly installed cable, who is to provide and install new cable?

The County

By: 
Melinda Bobbitt, CPPB
Purchasing Director

OFFEROR has examined copy of Addendum #2 to Request for Bid # **09-28FEB08 – Data and Telephone Terminations – Boone County Courthouse Renovation Project**, receipt of which is hereby acknowledged:

Company Name: _____
Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____