



BOONE COUNTY, MISSOURI
Request for Bid #09-28FEB08 – Data and Telephone Terminations – Boone County
Courthouse Renovation Project

ADDENDUM #3 - Issued February 25, 2008

This addendum is issued in accordance with the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.

The following question has been received for the above referenced bid and the following response is provided. Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

Question: Is Coastal Electric labeling the cabling they are pulling in or is the Contractor going to label it? If Contractor is labeling, will we just terminate and punch it in and give you a spread sheet, or will we need to tone and test each cable and label them in a specific order that you request?

Response: Coastal Electric will be labeling the cable they are pulling. The successful Contractor shall label the face plates and the patch panels in a specific way that the County will provide. The Contractor shall also test and certify each cable run.

By:


Melinda Bobbitt, CPPB

OFFEROR has examined copy of Addendum #3 to Request for Bid # **09-28FEB08 – Data and Telephone Terminations – Boone County Courthouse Renovation Project**, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____