

**ADDENDUM # 1  
BOONE COUNTY, MISSOURI  
WESTWOOD MEADOWS SUBDIVISION ASPHALT OVERLAY & ROADWAY DRAINAGE  
IMPROVEMENTS  
BID NO: 28 – 15 APR 08**

**ADDENDUM # 1**

**This addendum is issued in accordance with the Instruction to Bidders and hereby incorporated into and made a part of the Contract Documents.**

**Bidders are reminded that receipt of this addendum must be acknowledged and submitted with the attached Acknowledgment of Addendum Form and attached to your Bid Form.**

**Drawings and specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:**

**PROJECT REVISIONS / CLARIFICATIONS**

- 1. PLAN SHEET # 3: Retaining wall to be removed at 1660 Dawn Dr. – All timbers shall be removed and placed in owners front or side yard for reuse.**
- 2. PLAN SHEET # 3: - Relocation of Guy Wire and Utility Pole to be relocated by utility.**
- 3. Concrete Driveway Replacements– 5/8” rebar shall be pinned to existing concrete and placed at 18” centers each way. Steel shall be incidental to bid item.**

BIDDER has examined copies of all the Bidding Documents and of the following Addenda (receipt of all which is hereby acknowledged):

<u>DATE</u>	<u>ADDENDUM NUMBER</u>

COMPANY NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

PHONE NUMBER: \_\_\_\_\_

AUTHORIZED REPRESENTATIVE: \_\_\_\_\_