



**BOONE COUNTY, MISSOURI**  
**Request for Bid #: 05-28FEB11 – Chiller Installation**

**ADDENDUM #3 - Issued February 24, 2011**

This addendum is issued in accordance with the Introduction and General Conditions of Bidding in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

**I. A question was asked and an answer was given as follows:**

“Has CNC ever stated if they require a loncard or bacnet card?”

**The answer was given as follows:**

“The control contractor can use either.”

**II. A question was asked and an answer was given as follows:**

“The prints call out a refrigerant monitor location. Do you want this included in the bid as I don't think you currently have one, do you?”

**The answer was given as follows:**

“The refrigerant monitor should be furnished by the chiller manufacturer and mounted and wired by the control contractor.”

**By:**

\_\_\_\_\_  
**Tyson Boldan**  
**Buyer**

OFFEROR has examined copy of Addendum #3 to Request for Bid # **05-28FEB11 – Chiller Installation**, receipt of which is hereby acknowledged:

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Phone Number: \_\_\_\_\_ Fax Number: \_\_\_\_\_

Authorized Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Authorized Representative Printed Name: \_\_\_\_\_