

BOONE COUNTY, MISSOURI Request for Bid #: 27-23JUN11 - Rolling Hills Road Improvements Phase 1A-Utility Corridor Grading

ADDENDUM #2 - Issued June 21, 2011

This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum should be acknowledged and submitted with Offeror's Response Form.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. Plans - Sheet SQ1:

Clarification: Sheet SQ1 gives a tabulation of Earthwork (Utility Grading). This table gives estimated Earth Excavation, Rock Excavation and Compacted Embankment quantities for station 11+00 – 31+00, 31+00 – 51+00, and 51+00 to the end of project. An estimated shrinkage factor has been assigned to the Earth Excavation to give an estimated Volume of Compacted Embankment. Earth Excavation, Rock Excavation, and Compacted Embankment will be paid for as per Section 02300 of the Technical Specifications. All excess material shall be disposed of as per Section 02300. The Balance tabulation shown on SQ1 has had the shrinkage factor applied and is not meant to represent an estimated amount of excess material to be disposed of. The volume of excess material will vary based on actual shrinkage values, swell values and volume of rock excavation. No direct payment will be made for removal of unsuitable or excess material as described in Section 02300.

2. Additional Information:

The existing drainage structure under Rolling Hills Road on the South side of the intersection at Route WW has a posted load limit of 10 tons.

Bv


Tysor Boldan, Buyer Boone County Purchasing Approved:

Michael J. Purol

Professional Engineer MO Lic. # PE-2007002824

Poepping, Stone, Bach & Associates MO Engineering Corp. # 000534

801 Broadway Suite 224 Hannibal, MO 63401 Phone: 573-406-0541 Fax: 573-223-4605



OFFEROR has examined copy of Addendum #21 to Request for Bid # 27-23JUN11 - Rolling