




BOONE COUNTY, MISSOURI
Request for Bid #: 03-17JAN13 – Roof Replacement – Boone County Government Center

ADDENDUM #5 - Issued January 23, 2013

This addendum is issued in accordance with the Introduction and General Conditions of Bidding in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

Clarification: In an effort to clear up any misunderstandings concerning the Lightning Protection, the County expects to have an aluminum system replace the copper existing system on the roof top (Contractor bids as part of the Base Bid). It will be installed on top of the new parapet wall cap. Copper will be salvaged by the Lightning Protection provider (sub-contractor of the awarded Contractor) and a credit given in their charges.

By: 
Melinda Bobbitt, CPPB
Director of Purchasing

OFFEROR has examined copy of Addendum #5 to Request for Bid # **03-17JAN13 – Roof Replacement – Boone County Government Center** receipt of which is hereby acknowledged:

Company Name: _____
Address: _____
Phone Number: _____ Fax Number: _____
E-mail address: _____
Authorized Representative Signature: _____ Date: _____
Authorized Representative Printed Name: _____