



BOONE COUNTY, MISSOURI
Request for Bid #: 29-11JUL13 Oakland Church Rd. Micro Surfacing
Pavement Preservation 2013

ADDENDUM #1 - Issued July 3, 2013


This addendum is issued in accordance with the Request for Bid Project Plans and/or Details and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **SHOULD** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. This project will use Type 2 Micro-Surfacing as defined in Section 413.10 of the Special Provisions. The application rate shall be 20 – 22 lbs/sy.
2. The Micro-Surfacing shall be performed with a continuous machine.
3. A stockpile location will be available to the contractor at Boone County Public Works' North Facility located at 5501 Oakland Gravel Rd., Columbia, Missouri.

By: *Amy Robbins*
Amy Robbins, Buyer
Boone County Purchasing

Approved:



OFFEROR has examined copy of Addendum #1 to Request for Bid # 29-11JUL13– Oakland Church Road Micro Surfacing, Pavement Preservation 2013, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____