



BOONE COUNTY, MISSOURI
**Request for Bid #: 63-15OCT15 – Radio Tower Foundation and Site Construction for
the Emergency Communication Center**

ADDENDUM #1 - Issued October 7, 2015

This addendum is issued in accordance with the RFP Response Page in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum should be acknowledged and submitted with Offeror's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect.

- 1) In Section 1.01, add: "Fencing and landscaping by others."
- 2) In Section 1.10, add: "Fees for special inspections to be paid by Contractor."
- 3) In Section 2.01.a, add: "Drawing ME-2 shown for reference only."
- 4) In Section 2.02.a, add: "Thickness for shelter slab in 3/ME1 is 6 inches. Assume acceptable existing soil for construction of shelter and generator pads."
- 5) In Section 2.02.c, add: "Quantity of anchors determined after arrival of building. Typical example is 3/4" x 6-1/2" wedge anchor."
- 6) In Section 3.01.i, add: "Backfill material shall meet the requirements set out in Crockett geotech report section 4.1.3 "Structural Fill Requirements.""
- 7) In Section 4.01, add: "No submittals required under this section."

By:


Melinda Bobbitt, CPPO, CPPB
Director of Purchasing

OFFEROR has examined **Addendum #1** to Request for Bid # 63-15OCT15 – *Radio Tower Foundation and Site Construction for the Emergency Communication Center* receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

E-mail: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____