



BOONE COUNTY, MISSOURI
Request for Bid #: 66-27OCT15 – Generator Inspection Services

ADDENDUM # 1 - Issued October 9, 2015

This addendum is issued in accordance with the RFB Response Page in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should be acknowledged** and submitted with Offeror's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect.

- 1) Generators may be inspected prior to submitting a bid by contacting the following to set an appointment:

- a. For the Roger B Wilson Boone County Government Center, Robert L. Perry
Juvenile Justice Center, Boone County Courthouse**

Bob Davidson, Facilities Maintenance Manager

Phone: (573) 886-4401

bdavidson@boonecountymo.org

- b. For the Boone County Jail**

Captain Gary German

Phone: (573) 875-1111

ggerman@boonecountymo.org

- c. For Public Works**

Greg Edington, Assistant Manager, Road Maintenance Operations

Phone: (573) 449-8515

E-mail: gedington@boonecountymo.org

- 2) The County has received the following question and providing the response below:

- a.** Technical Specification 2.3.1.19 states "Test run generator (under load for 20 minutes) to check operational status of instruments. This is required on all quarterly inspections.

Primary Specification 2.1.3 states that the contractor shall test load generators at the five buildings outside of normal business hours 7:30 am – 5:00 pm.

Question: After reading both specifications, does this mean that all quarterly inspections will be bid on overtime hours since the generator test can only be done after hours?

Response: Maintenance crew actually runs the unit under load each quarter, after 7:30 p.m. at night. Generator Service will run for 20 minutes, not under load, to make sure it is running properly. The annual load test can be completed during the day with a load bank on a trailer.

By: Jacob M. Garrett By Malik S. Ho
Jacob M. Garrett, Buyer
Boone County Purchasing

OFFEROR has examined **Addendum #1** to Request for Bid# **66-27OCT15 – Generator Inspection Services** for Boone County receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

E-mail: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____