



BOONE COUNTY, MISSOURI
Request for Bid #06-24JAN17 – Standby Power Generator


ADDENDUM # 1 - Issued January 20, 2017

This addendum is issued in accordance with the RFB Response Page in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum should be acknowledged and submitted with Offeror's *Response Form*.

The following questions have been submitted and clarification reply are included:

1. Provide a site layout to determine pad location of Generator.
 - **The location of the pad is nearly contiguous to the building edge and at the far back corner of a narrow 'pocket' parking area. Boone County expect, but do not directly require, that the vendor contract with a crane operator to offload the generator at the mouth of the parking area with vendor delivery vehicle parked at the edge of Walnut street and then swing the generator into place on its pad. Depending on the ability to negotiate overhead wiring, it may require two picks with a reset.**
 - **Attached is a general site plan.**

By:



Jacob M. Garrett, Buyer
Boone County Purchasing

OFFEROR has examined **Addendum #1** to Request for Bid #06-24JAN17 – *Standby Power Generator*, receipt of which is hereby acknowledged:

Company Name: _____


Address: _____

Phone Number: _____ Fax Number: _____

E-mail: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____



LOCATION PLAN

SCALE: 1/32" = 1'-0"



Pechham & Wright Architects, Inc., d.b.a.
PWArchitects, Inc.
 2120 Forum Blvd., Ste. 101
 Columbia, Missouri 65203

DRAWING NO.
G001
 Sheet 1 of 1

PWArchitects.com
 573.449.2683
 Pechham & Wright Architects an Architectural Corporation
 Missouri State Certificate of Authority No. 000244

Parking lot-605 E. Walnut Street, Columbia MO

Boone County
Backup 911
Center-609 E.
Walnut Street

Proposed Generator location-
NE Corner of lot-see plan

