



BOONE COUNTY, MISSOURI
Request for Bid #: 23-25MAY17-River Oaks Rd. Culvert
Replacements-2017

ADDENDUM #1 - Issued May 3, 2017


This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. Location of the Pre-Bid Meeting has been modified. New location of Pre-Bid is as follows:

Pre-Bid Meeting
Tuesday, May 9, 2017 at 10:30 a.m.
Conference Room 332
801 E. Walnut
Columbia, MO, 65201

2. The storms of April 29-30 created a large scour hole from the outlet of Culvert 5990 to the edge of the road. Boone County road crews installed quarry run (9"x12") rip rap to stabilize the hole until construction. Contractor shall remove the rip rap from the scour hole and construct the culvert crossing as per Plan. The Contractor may haul the 9"x12" rip rap off site and include all costs into his Removal bid item, or may salvage the rip rap to be used in areas calling for Type 3 Rock Blanket. The bid quantities for Rock Blanket with Filter Fabric will remain the same to account for installation/labor costs. Any savings incurred from salvaging the 9"x12" rip rap shall be accounted for in the Contractor's bid unit price. It is not known how much 9"x12" rip rap was installed. The Contractor shall be responsible for making a site visit prior to bidding to estimate such quantities.

By: 
Phil Fichter, Buyer
Boone County Purchasing

Approved: Micah Taylor
Professional Engineer
MO Lic. # PE-2013019123

Boone County Resource Management
MO Engineering Corp. # N/A
801 E. Walnut, Room 315
Columbia, Missouri 65201
Phone: 573-886-4480
Fax: 573-886-4340



OFFEROR has examined copy of Addendum #1 to Request for Bid # 23-25MAY17-River Oaks Rd. Culvert Replacements-2017, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____