



BOONE COUNTY, MISSOURI
Request for Bid #: 25-08JUN17-Trenchless Culvert Rehab-
2017

ADDENDUM #2 – Issued June 5, 2017

This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:


1. Question: Are there exposed bolt heads on any of the culverts being lined with CCCP?

Answer: Yes, culverts #4117 and #4118 on Wagon Trail Rd. have exposed bolt heads. The CCCP liner design thickness, as indicated in the Plans, shall be measured from the surface of these bolt heads. It is estimated the bolts protrude roughly ¼" past the corrugation peak. Extra material needed to place proper design thickness over the bolts shall be included in the bid unit price.

By: 
Phil Fichter, Buyer
Boone County Purchasing

Approved: Micah Taylor
Professional Engineer
MO Lic. # PE-2013019123

Boone County Resource Management
MO Engineering Corp. # N/A
801 E. Walnut, Room 315
Columbia, Missouri 65201
Phone: 573-886-4480
Fax: 573-886-4340



OFFEROR has examined copy of Addendum #2 to Request for Bid # 25-08JUN17 Trenchless Culvert Rehab-2017, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____