



BOONE COUNTY, MISSOURI

Request for Proposal #: 29-15JUN18 – Used Radio Equipment Shelter

ADDENDUM #3 - Issued June 6, 2018

This addendum is issued in accordance with the Response Page in the Request for Proposal and is hereby incorporated into and made a part of the Request for Proposal documents. Offerors are reminded that they should acknowledge receipt of this addendum and submit it with Offeror's Response Form.

Specifications for the above noted Request for Proposal and the work covered thereby are modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect.

I. The County received the following question and is provided a response.

3.2.1. General configuration will be shelter installed East-West, lengthwise. This means the long walls will be E-W and the short walls N-S.


3.2.5. Configuration

A. Shelter should have two wall-mounted Air Conditioning units mounted on east short wall.

B. Entry door should be on south facing long wall.

C. Two cable entry panels (or provision for panels to be relocated or installed) should be to a 'high mount' position on north facing long wall.

Question: Based on 3.2.5 B. This is how the building is to be placed?



Response: The depiction is correct. Prefer the door anywhere along south wall.

By:


Melinda Bobbitt, CPPO, CPPB
Director of Purchasing

Offeror has examined **Addendum #3** to Request for Proposal # **29-15JUN18 – Used Radio Equipment Shelter**, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

E-mail: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____