

Facility	Equipment Type	Manufacturer	Model	Version	Keypads	Doors	Glassbreak's	Motion Detectors	Heat Detectors	Smoke Detectors	Panic Buttons	Communications	Notes
Boone County Annex, 613 E Ash	Fire/Burglar	DMP	X150	106	2	4 - Wireless	3 - Hardwired	2 - Hardwired			9 - wireless	Network	1 Main fire alarm panel, 5 smoke detectors, 1 duct sensor, 4 pull stations.
Johnson Warehouse/Public Defender/Records Storage/Surplus - 1 panel, 2 partitions	Fire/Burglar	GE	Concord		4	8 - Wireless				4 - wireless	2 - wireless	Telco	1 control panel, 2 partitions
Public Defender Elevator Fire system	Fire	DMP	X8500N							3 - hardwired		Telco	
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, Secure Hall	Fire/Burglar	DMP	X8500N	212	2	2 - Hardwired	6 - hardwired	2 - hardwired				Network/Telco backup	1 control panel, 7 partitions.
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, Clerks Warehouse	Fire/Burglar				1	2 - Hardwired		6 - hardwired				Network/Telco backup	
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, Vehicle Processing	Fire/Burglar				1	2 - Hardwired						Network/Telco backup	
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, Loading Dock	Fire/Burglar				1	3 - hardwired						Network/Telco backup	
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, Evidence	Fire/Burglar				1	2 - Hardwired						Network/Telco backup	
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, Basement Storage	Fire/Burglar				1	1 - hardwired		1 - hardwired				Network/Telco backup	1 - hardwired water bus system, 1 - hardwired refrigerator/freezer temp monitor
Boone County Sheriff's Department Annex - 1 panel, 7 partitions, common	Fire/Burglar				1	4 - hardwired	4 - hardwired	2 - Hardwired		more than 5 hardwired		Network/Telco backup	2 - hardwired duct detectors, 2 - hardwired sprinkler tamper, 1 - sprinkler flow, 10 - pull stations
Boone County Road & Bridge	Fire/Burglar	DMP	X8500N	213	2	17 - hardwired		11 - hardwired	15+ - hardwired	2 - hardwired		Network/Telco backup	8 - hardwired pull stations
Prosecuting Attorney Child Support Division	Fire/Burglar	GE	Concord		1	2 - wireless		1 - wireless, 1 hardwired		3 - wireless		Telco	
Boone County Courthouse	Fire/Burglar	DMP	X8500N		1	11 - hardwired	43 - hardwired		3 - hardwired	34 -		Telco	10 - duct detectors, 17 - pull stations
Boone County North Facility	Fire/Burglar	DMP	X8200		3	8 - hardwired		3 - hardwired	1 - hardwired			Telco	
Boone County Government Center - 1 panel, 4 partitions	Fire/Burglar	DMP	X8500N	207	6	4 - hardwired, 1 - wireless	8 - hardwired	5 - hardwired	2 -	11 -	28 - wireless	Network/Telco backup	2 connected fire alarm panels, 2 - duct detectors, 15 - pull stations
Boone County Government Center - Clerk	Fire/Burglar				1	3 - hardwired		1 - hardwired				Network/Telco backup	
Boone County Government Center - Collector	Fire/Burglar				2	2 - hardwired	7 - hardwired	2 - hardwired				Network/Telco backup	
Boone County Government Center - Treasurer	Fire/Burglar				1	1 - hardwired		1 - hardwired				Network/Telco backup	
Boone County Juvenile Justice Center													
Boone County Joint Communications Backup Center	Fire/Burglar	Bosch	D7412GV4		2	2 - hardwired	2 - hardwired	2 - hardwired				Telco, network available.	1 connected fire alarm panel.