

Minimum Septic System Setbacks

Prepared by Boone County Resource Management


NOT TO SCALE. FOR DEMONSTRATION PURPOSES ONLY

ROAD

Proposed House Location



Septic Tank



15'



Water Well (Private)

50'

100'

PROPERTY LINE

Disposal Area**

10'

300'

300'

Accessory Structure



15'

Water Well (Public)



*Hydrologic or low lying areas may have regulatory stream buffer or FEMA Floodplain. Additional restrictions will apply for environmentally sensitive areas. See staff for further details.

All septic site plans **ARE REQUIRED to identify the type of dispersal product to be used and calculations for designing the system.

Stream Buffer/FEMA Floodplain*

Lake, Stream, Water Feature

50'